

Certificate of constancy of performance,

0832-CPR-F1133

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

801722 Addressable Dual Channel Aspirating Detector

(For full product details and conditions of use refer to appendix)

Produced by or for

Esser by Honeywell

**Novar GmbH
Dieselstrasse 2
41469 Neuss
Germany**

and produced in the manufacturing plant(s)

Pittway Technologica Srl

**Via Caboto 19/3
34147 Trieste
Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-20:2006 - Aspirating smoke detectors

EN 54-18:2005 - Input/output devices

EN 54-17:2005 - Short circuit isolators

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 28 September 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Steve Patrick, Business Group Manager
On behalf of BRE Global Limited
Date of issue: 28 September 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F1133

Bases:

B501AP Intelligent Sensor Base

Note:

1. Incorporating an Esser Alarm transponder 808623



Steve Patrick, Business Group Manager
On behalf of BRE Global Limited
Date of issue: 28 September 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.