

CERTIFICATE

0960-CPR-SKGIKOB.009676.01.EN

Issued: 22-12-2015
Valid until: 22-12-2020



Certificateholder

Honeywell Analytics Ltd.
Hatch Pond House
4 Stinsford Road
Nuffield Industrial Estate,
BH17 0RZ Poole
T: +44 (0) 1202 6761 61
E: gasdetection@honeywell.com
I: www.honeywellanalytics.com

Certificate of constancy of performance

Declaration of SKG-IKOB (Notified Body 0960)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

FLAME DETECTORS

as specified in the attached appendix placed on the market under the name or trade mark of the holder of this certificate and produced by the holder of this certificate or for the holder of this certificate in the manufacturing plant(s) if mentioned above.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-10:2002

and

EN 54-10:2002/A1:2005

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

This certificate was first issued on 22-12-2015 and will remain valid until the date as mentioned at this certificate as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized 'H' and 'A' followed by a horizontal line.

ir. H.A.J. van Dartel
Certification manager

The users of this certificate are advised to verify at www.skgikob.nl if this certificate is still valid and actual.
This certificate consists of 2 pages.

SKG-IKOB Certificatie
Poppenbouwing 56
4191 NZ Geldermalsen

Postbus 202
4190 CE Geldermalsen

T 088-2440100
info@skgikob.nl
www.skgikob.nl

CERTIFICATE

CERTIFICATE

Honeywell Analytics Ltd.

Number: 0960-CPR-SKGIKOB.009676.01.EN

Page 2 of 2

Appendix 1

CERTIFICATE OF CONSTANCY OF PERFORMANCE

| Article | Specification | Classification according to EN 54-10 | SKG-IKOB - ITT (report nr.) |
|-----------------|----------------------------|---|--------------------------------|
| FSL 100-IR3-(W) | Infrared Flame Detector | Class 1 | 15.00633 |

| Article | Specification | Classification according to EN 54-10 | SKG-IKOB - ITT (report nr.) |
|----------------|-------------------------------|---|--------------------------------|
| FSL 100-UV-(W) | Ultraviolet Flame Detector | Class 2 | 11-407 13.00220 |

| Article | Specification | Classification according to EN 54-10 | SKG-IKOB - ITT (report nr.) |
|------------------|--|---|--------------------------------|
| FSL 100-UVIR-(W) | Ultraviolet / Infrared Flame Detector | Class 2 | 11-407 |