

## Construction Products Regulations (305/2011/EU – CPR)

### Declaration of Performance – 26674

#### 1. Unique identification code of the product type: Xtralis VESDA-E (VEU)

##### Models:

VEU-A00	VESDA-E VEU with LED display only
VEU-A10	VESDA-E VEU with 3.5" LCD display
VEU-A00-P	VESDA-E VEU with LED display only plastic enclosure
VEU-A10-P	VESDA-E VEU with 3.5" LCD display plastic enclosure

##### French versions:

VEU-A00-NF	VESDA-E VEU with LED display only
VEU-A10-NF	VESDA-E VEU with 3.5" LCD display
VEU-A00-P-NF	VESDA-E VEU with LED display only plastic enclosure
VEU-A10-P-NF	VESDA-E VEU with 3.5" LCD display plastic enclosure

##### Remote Units

VRT-100	Remote Programmer
VRT-200	Remote Display (VLP) with 7 relays
VRT-300	VESDAnet socket
VRT-500	Remote Relay unit with 7 relays
VRT-600	Remote Display (VLP) with no relays
VSR-xxxx	These remote units may be rack mounted

##### Ancillaries:

E700-FILASSY	In line filter
VSP-850	In line filter

#### 2. Intended use:

Aspirating smoke detectors for use in fire detection and fire alarm systems installed in and around buildings

#### 3. Manufacturer:

Xtralis Pty Ltd  
4 North Drive, Virginia Park  
236-262 East Boundary Road  
Bentleigh East  
Victoria 3165  
Australia

#### 4. European address:

Xtralis UK Ltd  
Peoplebuilding  
Ground Floor  
Maylands Avenue  
Hemel Hempstead  
Herts HP2 4NW

**5. System of assessment of continuity of performance (AVCP):** System 1

**6. The products are certified to the harmonised standard(s) identified in the table below by:**

*VdS Schadenverhütung GmbH  
Amsterdamer Str. 174  
D-50735 Cologne  
Germany*

*Notified Body Number: 0786*

who have performed product type tests, initial inspection and subsequent surveillance of factory production control under system 1 and have issued the following certificates:

- EC Certificate of Constancy of Performance: *0786-CPR-26674*

**7. Declared Performance:** See next page

**8. Declaration:**

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified in point 3.

**Signed for and on behalf of the manufacturer**

Name: Samir Samhour

Position: CEO

Signature:



Date: November 10, 2014

For aspirating smoke detectors the following table applies

Harmonised Technical Specification		EN 54-20:2006
Essential characteristics	Performance	Clause
Nominal activation conditions/sensitivity/response delay and performance under fire conditions:		
Response to slowly developing fires	<i>pass</i>	5.6
Repeatability	<i>pass</i>	6.2
Reproducibility	<i>pass</i>	6.3
Fire sensitivity (Class A, B &/or C)	<i>Class A,B &amp; C<sup>(1)</sup></i>	6.15
Operational reliability:		
Individual alarm indication	<i>pass</i>	5.2
Connection of ancillary devices	<i>pass</i>	5.3
Manufacturer's adjustments	<i>pass</i>	5.4
On-site adjustment of behaviour	<i>pass</i>	5.5
Mechanical strength of the pipework	<i>pass</i>	5.7
Components in the sampling device	<i>pass</i>	5.8
Airflow monitoring	<i>pass</i>	5.9
Power supply	<i>pass<sup>(2)</sup></i>	5.10
Data	<i>pass</i>	5.11
Software controlled detectors	<i>pass</i>	5.12
Tolerance to supply Voltage:		
Variation in supply parameters	<i>pass</i>	6.4
Durability of operational reliability:		
Temperature resistance:		
Dry heat (operational)	<i>pass</i>	6.5
Cold (operational)	<i>pass</i>	6.6
Vibration resistance		
Shock (operational)	<i>pass</i>	6.10
Impact (operational)	<i>pass</i>	6.11
Vibration sinusoidal (operational)	<i>pass</i>	6.12
Vibration sinusoidal (endurance)	<i>pass</i>	6.13
Electrical stability:		
Electromagnetic compatibility (EMC), immunity	<i>pass</i>	6.14
Humidity resistance:		
Damp heat, steady state (operational)	<i>pass</i>	6.7
Damp heat, steady state (endurance)	<i>pass</i>	6.8
Corrosion resistance:		
SO2 corrosion (endurance)	<i>pass</i>	6.9

(1) The class of any pipe/hole configuration and detector sensitivity is determined using ASPIRE-E

(2) The detector should be supplied with power from a power supply conforming to EN 54-4